

Lumen Pad Stem Mounting instructions for LCMPD18R

WARNING Risk of fire or electric shock. Only qualified, licensed electricians should install Delray Lighting products.

- 1. Read and review all instructions and diagrams prior to installation.
- 2. Disconnect power prior to installation. Turn off circuit breaker or remove fuse from fuse panel. (Turning off the light switch is insufficient to safeguard against electric shock.)
- 3. Electrical connections must conform to local codes and ordinances, or the National Electrical Code.
- 4. Wire the luminaire following the wiring diagram on the driver, or inside the box. Use UL listed wire connectors suitable for the size, type, and number of conductors. No loose strands or wires should be present. Secure wire connectors with UL listed electrical tape and wire nuts.
- 5. Restore electricity and test fixture.


Tools Required


NOTE: These safeguards and instructions are not intended to cover all possible conditions and circumstances. Proceed with caution; utilizing established professional electrical installation methods, tools, and supplies.


IMPORTANT: Please read these instructions before commencing installation and retain for future reference.

Components


Wood screws X3

























Wire nuts X3







Power Drill

Important Safety Information

Please read these instructions carefully before attempting to install this product. It is advisable to keep these instructions in a safe place for further reference.

WARNING: All electrical connections must be in accordance with local and National Electrical Code (N.E.C.) standards. If you are unfamiliar with proper electrical wiring connections obtain the services of a qualified electrician.

WARNING: RISK OF SHOCK House electric current can cause painful shock or serious injury unless

- A. Turn off the power Supply at the fuse or circuit breaker box before you install the fixture
- B. Ground the fixture to avoid potential electric shocks and to ensure reliable starting.
- C. Double-check all connections to be sure they are tight and correct.
- D. Wear rubber soled shoes and work on a sturdy wooden ladder.

WARNING: Risk of fire. Use only on 120-277 volt 60Hz circuits. Suitable for damp locations. Before installing your lighting fixture, thoroughly review enclosed installation manual.

CAUTION: TURN OFF THE MAIN POWER AT THE CIRCUIT BREAKER BEFORE INSTALLING THE FIXTURE. IN ORDER TO PREVENT POSSIBLE SHOCK.

This fixture is designed for use in a circuit protected by a fuse or circuit breaker. It is also designed to be installed in accordance with local electrical codes. If you are unsure about your wiring, consult a qualified electrician or local electrical inspector, and check your local electrical code.

WARNING: RISK OF CUTS Some metal parts in the fixture may have sharp edges. To prevent cuts and scrapes, wear gloves when handling the parts.

Account for small parts and destroy packing material, as these may be hazardous to children.

Matintenance & Care

- 1. Ensure that the power is disconnected prior to cleaning.
- 2. To keep the finish of this product, wipe over with soft cloth periodically.
- 3. Do not use harsh chemical solvents, it may dis-colour or damage the finish.

Preparation for Installation

- 1. Read these instructions carefully before attempting to install this product.
- 2. Disconnect electrical power before installing or servicing any part of this fixture.
- Place fixture on a clean flat surface.





Lumen Pad Stem Mounting instructions for LCMPD18R


WARNING Risk of fire or electric shock. Only qualified, licensed electricians should install Delray Lighting products.

- 1. Read and review all instructions and diagrams prior to installation.
- 2. Disconnect power prior to installation. Turn off circuit breaker or remove fuse from fuse panel. (Turning off the light switch is insufficient to safeguard against electric shock.)
- 3. Electrical connections must conform to local codes and ordinances, or the National Electrical Code.
- 4. Wire the luminaire following the wiring diagram on the driver, or inside the box. Use UL listed wire connectors suitable for the size, type, and number of conductors. No loose strands or wires should be present. Secure wire connectors with UL listed electrical tape and wire nuts.
- 5. Restore electricity and test fixture.

NOTE: These safeguards and instructions are not intended to cover all possible conditions and circumstances. Proceed with caution; utilizing established professional electrical installation methods, tools, and supplies.


Install mounting plate

Drill holes in the ceiling or wall aligned with the key holes located in the mounting plate (A), insert the plastic anchors (C) into ceiling or wall and secure mounting plate with wood screws (D). (shown in Fig. 1)




2. Connect wires

Attache safety harness to junction box. Then, use wire nuts (E) to connect all wires. Ensure all wires are joined securely. (shown in Fig. 2 and Fig. 4)




3. Install fixture

Twist and lock the fixture, onto the mounting plate, until secured. (shown in Fig. 3)



Connect details



CAUTION

WARNING: Risk of fire. Use only on 120-277 volt 60Hz circuits. Suitable for damp locations. Before installing your lighting fixture, thoroughly review enclosed installation manual. If you do not have sufficient electrical wiring experience, please refer to a do-it-yourself wiring handbook or have your fixture installed by a qualified licensed electrician. All electrical connections must be in accordance with Local and National Electrical Code (NEC) Standards. Reliable operating temperature is 0°F-120°F. If flickering occurs in low level dimming, increase light level. Compatible with most dimmers. Dimmable to 10% with most dimmers. For more information including dimmer compatibility visit www.liton.com.

www.liton.com

Technical drawings for illustration purposes only. Liton has the right to change any information without prior notice. Make sure you check all hole cut outs before work commences.

