

CATALOG # : LWMLD4C23/LWMLD4C3/LWMLD4CJ3

SAVE THESE INSTRUCTIONS

Keep these instructions in a safe place for future use/reference.

Important: Please read and understand all instructions completely before installing this fixture.

WARNING: Fixture installation (and use) and all electrical connections must be in accordance with local and National Electrical Codes (N.E.C.) rules, regulations and standards. If you are unfamiliar with installing fixture(s), accessories and/or electrical wiring have a qualified licensed electrician install this fixture for you. Fixture should be installed by a qualified electrician.

WARNING: RISK OF SHOCK. House electric current can cause painful shock or serious injury.

WARNING: Always disconnect power before fixture installation, wiring, or maintenance.

WARNING: Before starting the wire connections, disconnect the power by turning off the circuit breaker or removing the fuse at the fuse panel. Turning the power off using the light switch is not sufficient to prevent electrical shock.

This luminaire must be connected with supply wire/conductors rated at 90°C. Most dwellings built before 1985 have supply wire rated at 60°C; consult a qualified electrician before installing.

WARNING: Before service insure fixture is cool to touch.

WARNING: Check fixture for input voltage before connecting power to fixture.

WARNING: RISK OF SHOCK. This fixture is suitable for dry locations only.

WARNING: Do not install any fixture or assembly (etc.) closer than 6" from any curtain, or similar combustible material.

Fixture must be installed on a circuit protected by Ground Fault Circuit Interrupter (GFCI).

Install LED fixture(s)/LED driver(s) only on their own circuit. Do not mix any other products (Incandescent, Compact Fluorescent, H.I.D. products/fixtures, etc...) with LED fixture(s)/LED driver(s) on a single circuit.




Do not use any other electrical equipment (example: surge protector photocell, etc.) that is not (rated) for use with LED fixture(s)/LED driver(s) on the same circuit as LED fixture(s)/LED driver(s).

Install remote surge protector(s) (by others, goes on the circuit with nothing between the surge protector and the LED fixture(s)/LED driver(s)), if the fixture is not already installed with a surge protector, to help remove power surges that may harm LED fixture(s), appropriate for the installation. Periodically check and make sure that your remote surge protector(s) are in good working order.

Components / Parts

Components Dimensions

Tools Required



- Phillips Head Screwdriver
- Wire Connectors
- Hardware (screws, nuts, etc.)
- DO NOT USE POWER TOOLS.
ONLY USE HAND TOOLS.

FIG. 1

FIGURE 1: FIXTURE INSTALLATION

NOTE: Fixtures may be mounted on the wall or ceiling (see FIG 1 below left for mounting locations)


1. Remove Univesal Mounting Bracket (UMP) from Canopy.
2. Univesal Mounting Bracket (UMP fits to all standard electrical junction boxes that have 2-3/4" to 3-1/2" hole/screw spacing (see above dimensions), for example: 3-1/2" & 4" octagonal j-boxes. Other j-boxes may also fit UMP. Make sure j-box will fit slots or holes on UMB.
3. Install wiring and j-box in ceiling, if needed.
4. Secure (2) 8-32 x 1/2" long pan head screws in Univesal Mounting Bracket 8-32 tapped holes (FIG 1).
5. Secure Univesal Mounting Bracket (UMP) to j-box (by others) with appropriate hardware (by others) (FIG 1).
6. Connect the power supply wiring (from j-box) to fixture wiring in j-box. See "Wiring" instructions below.
7. Align the (2) 8-32 x 1/2" screws (by others) in the UMB through the fixture canopy and secure with cap nuts.

RELAMPING Return fixture to Liton for servicing/replacing LED and LED drivers.

WIRING

NOTE: Check fixture for input voltage before connecting power to fixture. Connect wiring in j-box. For dimming information (wiring diagrams, chart, etc.) see fixture's website page.

1. Connect ground wire (green or bare copper/aluminum) from the supply circuit to the ground wire (green or bare copper) /screw/connector from the fixture.
2. Connect the neutral (common) wire from the power supply circuit to the neutral wire from the fixture.
3. Connect the main voltage supply wire (line/lead) from the power supply to the line (lead) wire from the fixture.
4. Secure connection using UL Listed wire nuts/connectors and then with UL Listed Electrical tape (by others), as required, appropriate for the connection.



Mounting Locations
LWMLD4C23 (Shown wall mount).
LWMLD4C3 & LWMLD4CJ3
(For ceiling and wall mount)